

State of California
Well Completion Report
 Form DWR 188 Auto-Completed 2/27/2017
 WCR2016-006241

Owner's Well Number D00249 Date Work Began 08/11/2016 Date Work Ended 08/16/2016
 Local Permit Agency Environmental Health Services of Monterey County
 Secondary Permit Agency _____ Permit Number 16-12646 Permit Date 04/26/2016

Well Owner (must remain confidential pursuant to Water Code 13752)	Planned Use and Activity
Name <u>XXXXXXXXXXXXXXXXXXXX</u>	Activity <u>New Well</u>
Mailing Address <u>XXXXXXXXXXXXXXXXXXXX</u> <u>XXXXXXXXXXXXXXXXXXXX</u>	Planned Use <u>Water Supply Irrigation - Agriculture</u>
City <u>XXXXXXXXXXXXXXXXXXXX</u> State <u>XX</u> Zip <u>XXXXX</u>	

Well Location	
Address <u>899 ROSITA RD</u>	APN <u>012-551-006</u>
City <u>DEL REY OAKS</u> Zip <u>93940</u> County <u>Monterey</u>	Township <u>15 S</u>
Latitude _____ N Longitude _____ W	Range <u>01 E</u>
Deg. Min. Sec. Deg. Min. Sec.	Section <u>27</u>
Dec. Lat. <u>36.5964655</u> Dec. Long. <u>-121.8485616</u>	Baseline Meridian <u>Mount Diablo</u>
Vertical Datum _____ Horizontal Datum <u>WGS84</u>	Ground Surface Elevation _____
Location Accuracy _____ Location Determination Method _____	Elevation Accuracy _____
	Elevation Determination Method _____

Borehole Information	
Orientation <u>Vertical</u> Specify _____	
Drilling Method <u>Direct Rotary</u> Drilling Fluid <u>Bentonite</u>	
Total Depth of Boring <u>130</u> Feet	
Total Depth of Completed Well <u>110</u> Feet	

Water Level and Yield of Completed Well	
Depth to first water _____	(Feet below surface)
Depth to Static _____	
Water Level <u>5</u> (Feet)	Date Measured <u>08/16/2016</u>
Estimated Yield* <u>40</u> (GPM)	Test Type <u>Air Lift</u>
Test Length <u>2</u> (Hours)	Total Drawdown _____ (feet)
*May not be representative of a well's long term yield.	

Geologic Log - Free Form		
Depth from Surface	Feet to Feet	Description
0	20	Top soil & sand
20	40	Sand, gravel & sandstone
40	60	Blue shale & sandstone
60	100	Black shale
100	120	Black shale & rock
120	130	Black shale

Casings										
Casing #	Depth from Surface Feet to Feet		Casing Type	Material	Casings Specificatons	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0	60	Blank	PVC	OD: 5.563 in. SDR: 21 Thickness: 0.265 in.	0.265	5.563			
1	60	100	Screen	PVC	OD: 5.563 in. SDR: 21 Thickness: 0.265 in.	0.265	5.563	Milled Slots	0.032	
1	100	110	Blank	PVC	OD: 5.563 in. SDR: 21 Thickness: 0.265 in.	0.265	5.563			

Annular Material					
Depth from Surface Feet to Feet		Fill	Fill Type Details	Filter Pack Size	Description
0	50	Cement	10.3 Sack Mix		
50	130	Filter Pack	8 x 16		

Other Observations:

Borehole Specifications		
Depth from Surface Feet to Feet		Borehole Diameter (inches)
0	130	10.75

Certification Statement			
I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief			
Name	MAGGIORA BROS DRILLING INC		
	Person, Firm or Corporation		
595 AIRPORT BLVD	WATSONVILLE	CA	95076
Address	City	State	Zip
Signed	<i>electronic signature received</i>	09/06/2016	249957
	C-57 Licensed Water Well Contractor	Date Signed	C-57 License Number

DWR Use Only																							
CSG #	State Well Number			Site Code	Local Well Number																		
<table border="1"> <tr> <td> </td><td> </td><td> </td><td> </td><td>N</td> </tr> </table>								N	<table border="1"> <tr> <td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td>W</td> </tr> </table>														W
				N																			
										W													
Latitude Deg/Min/Sec				Longitude Deg/Min/Sec																			
TRS:																							
APN:																							